

Energy & Store
Development Conference

2013
E+Sd



THE VOICE OF FOOD RETAIL 


Energy & Store
Development Conference

E+Sd

2013


**How Different Condensers and
Refrigerants Affect Total
Refrigeration System Energy
Consumption**

- Refrigeration system \approx 50% total store energy
- Compressor + condenser \approx 60 – 70% refrigeration system



Electricity Billing

- Kilowatt = rate of energy use
- Kilowatt-hour = quantity of energy used
- Electricity charge = [total kWh/month] * \$/kWh
- Demand charge = [peak kW/month] * \$/kW




Refrigerant

Air

Conventional Air Cooled

Sensible heat transfer = temperature change




Refrigerant

Air

Water

Conventional Evaporative

Latent heat transfer = phase change
(evaporation)




Refrigerant


Air

Water

Dry Coil Hybrid Condenser




Wet bulb and dry bulb temp
Hybrid heat transfer
High MBH/hp
Small footprint
No water treatment



Condenser Types Summary

	Air Cooled	Hybrid	Evaporative
Ambient Heat Sink Temp	Dry Bulb	Dry Bulb AND Wet Bulb	Wet Bulb
Design Condensing Temp	105 – 120F	90 – 105F	90 – 105F
Efficiency	Lowest MBH/hp	High MBH/hp	Highest MBH/hp
Peak kW and Total kWh	Highest	Lower	Lowest
Footprint	Largest	Smaller	Smallest
Water Required	None	Water	Water + treatment



Case Study: Edina, MN

Pilot Store Retrofit

Before: Five Air-cooled Condensers




After: Five Hybrid Condensers




Total Store: 50F Day

Before




After




Total Refrigeration: 50F Day

Before




After




Total Fan Power: 50F Day


Before




After



Total Store: 100F Day Before




After




Total Refrigeration: 100F Day


Before




After



Total Fan Power: 100F Day Before




After




Summary

- Avg refrigeration savings 35 - 110 kW max
- Avg annual savings \$24.5K - \$77K max
- Realistic annual savings weather \$30 -35K



Pilot Store: Actual vs Estimated kW Savings




Actual, with Air Cooled	130	230
Actual Saved	35	110
Estimated Saved	24	84

Energy Analysis: Simple System

Air cooled vs hybrid vs
evaporative

150 Tons R407a, +20F ST, Wash DC



150 Tons R407a, +20F ST, Wash DC

- Air Cooled Condenser, Staged
- Evaporative Condenser, VFD
- TrilliumSeries™ Condenser, VSEC

Wash DC Design: 94.3DBT / 76WBT

Total kW

Evap Dry
Operation


Air Cooled Fan
Stages

Hybrid Wet
Operation


kW = compressor + condenser fans/pumps

Ambient DBT

-4.5 -0.5 3.5 7.5 11.5 15.5 19.5 23.5 27.5 31.5 35.5 39.5 43.5 47.5 51.5 55.5 59.5 63.5 67.5 71.5 75.5 79.5 83.5 87.5 91.5 95.5 99.5 103.5



150 Tons R407a, +20F ST, Wash DC



Summary: R407a

Total kWh/yr	Air Cooled	Hybrid	Evaporative
R407a	932,561	866,251	842,786

Energy Savings



7%



10%



Peak kW	Air Cooled	Hybrid	Evaporative
R407a	227	171	152

Peak Demand Reduction



25%



33%




Energy Analysis: Simple System

R407a vs R717

\$0.12/kWh

150 TR System, +20F Suction, Washington DC



■ R-407A
■ R-717

932,561

866,251
738,549

842,786
694,775

9%
\$11K


15%
\$15K

26%
\$29K

18%
\$18K

\$11/kW Peak, 150 TR System, +20F Suction, Washington DC

80% ratchet



44%
\$10,780


4%
\$862


13%
\$2,372

16%
\$2,587


Energy Analysis: Simple System

Total Cost of Ownership Summary





Summary: Carbon Footprint





Preston Blay: pblay@baltimoreaircoil.com

Paul Noreen: pnoreen@baltimoreaircoil.com