

Energy & Store  
Development Conference


E+Sd

2015



# **Reducing Utility Consumption = A Better Bottom Line**

**Ian Crookston, CEM, CMVP, P. Eng.  
Sobeys Inc.**



# About Sobeys Inc.

- Established in 1907
- One of Canada's two national grocery retailers
- \$21 Billion in annual sales & 125,000 employees and franchise affiliates
- More than 1,500 stores across all 10 provinces, as well as more than 370 retail fuel locations
- Retail banners include Sobeys, Safeway, Thrifty Foods, IGA, Foodland, FreshCo and Lawton's Drugs









# Canadian Environment

- **10 Million km<sup>2</sup> & 36 Million people**
  - 3.4 people/km<sup>2</sup>
- **ASHRAE Climate Zones**
  - 4 (Vancouver, British Columbia) / 8 (Whitehorse, Yukon Territories)
- **Energy (average cost)**
  - Electricity (at plug): \$0.07 to \$0.15/kWh
  - Natural Gas (at burner tip): \$0.02 to \$0.08/kWh (\$6 to \$23/GJ)
- **CO<sub>2</sub> impact**
  - Electricity: 0.002 (Manitoba) to 0.841 (Alberta) CO<sub>2e</sub> tonne/kWh → 420:1 ratio
  - Refrigerant: 0.0010 (R744 / CO<sub>2</sub>) to 3.3 (R507) CO<sub>2e</sub> tonne/kg → 3,300:1 ratio
  - Taxes: \$0.00/tonne (at present; but significant future risk)
- **Energy usage (Sobeys)**
  - Refrigeration: >60% (we design a refrigeration rich environment)





# Cost Saving Vs Cost Avoidance

- **Cost Saving: Reduce \$/ft<sup>2</sup>**

- Not possible if rates (\$/kWh) are rising faster than ability to reduce energy intensity (kWh/ft<sup>2</sup>)
- Cost Savings (\$) =  $(\$/\text{ft}^2_{\text{Old}} - \$/\text{ft}^2_{\text{New}}) * (\text{ft}^2_{\text{New}})$

- **Cost Avoidance: Reduce kWh/ft<sup>2</sup>**

- A truer measure of achievement
- How we track progress for sustainability reporting
- Cost Avoidance (\$) =  $(\text{kWh}/\text{ft}^2_{\text{Old}} - \text{kWh}/\text{ft}^2_{\text{New}}) * (\$/\text{kWh}_{\text{New}}) * (\text{ft}^2_{\text{New}})$




# Energy Conservation

- **Provincial incentives (\$/kWh)**


- Typically reduce Simple Payback by one year
- One time benefit, which can increase, or decrease
- Vary by province

- **Rates (\$/kWh)**

- Ongoing cost, which typically only increases
- Vary by province








# Typical Full Service Format Store


- ~50,000 ft<sup>2</sup>
- **Electricity**
  - ~\$35/hour x 8,760 hours/year = \$300,000/year
  - Refrigeration represents ~60% (\$180,000)
- **Centralized refrigeration racks**
  - Medium temperature: 5 to 7 compressors
  - Low temperature: 5 to 7 compressors





# What Did We Do?

- **Picked a test site**
  - Southern Ontario
  - 42,000 ft<sup>2</sup>
  - Built: 1991
- **Contacted Local Distribution Company (LDC)**
  - SaveONenergy incentives
- **Baseline existing system**
- **Developed series of projects**
  - Project #1: Existing Building Commissioning
  - Project #2: Adiabatic cooling (condenser misting)
  - Project #3: Variable flow compressors




# Thermodynamic Model

- **Thermodynamic evaluation = Unbiased system view**

- No information about external loads, compressors, etc.


- Electrical sub-metering, temperatures and pressures



- 2 pressure sensors
- 7 temperature sensors
- 1 power meter



# System Specific Flowchart







# Baseline Existing System

- Performance monitoring and analyzing system

- Real time data logging

- Electrical sub-metering, temperatures and pressures at one minute intervals






# Power Profile – Measurement & Verification Tool

- **Power Profile**

- Average kWh at each Outdoor Ambient Temperature (OAT)
- Averaged over one hour
- Averaged by additional data points


- **Measurement & Verification (M&V)**

- Pre and post project Power Profile (kW/°C)
- Bin Temperature data (°C hours)
- kWh/year savings



— Nominal Profile - - Optimized Profile






# System Efficiency Index (SEI)

- **Normalized unit of absolute efficiency**
- **Introduced by VDMA (Germany) and IOR (UK)**
- **100% SEI: System operating at ideal theoretical efficiency (Carnot Cycle)**
- **Independent of operating conditions**
  - Coefficient of Performance (COP), Energy Efficiency Ratio (EER), Etc. based on design/standard conditions
    - Saturated Suction Temperature
    - Condensing Temperature
- **Evaluation of sub-system performance**
  - Compressor (Isentropic efficiency)
  - Evaporator
  - Condenser
  - Auxiliary loads



# System Efficiency Index (SEI)

- **SEI independent of outdoor ambient temperature**
  - Should be consistent across wide range of temperatures
  - Changes Vs temperature represent issues with sub-system performance
    - Doesn't always show up on the Power Profile
  - Differences between systems represent overall efficiency differences






# Project #1: Existing Building Commissioning (EBCx)

- Low / No cost optimization
- Opportunities based on reviewing baseline data
  - Setpoints
  - Sequencing
  - Condenser fan control







**Before: Short cycling**

# Project #1: Before & After


**After: Reduced Cycling**




**Before: Fluctuating Power**




**After: Stable Power**



**Before: Erratic Condensing**




**After: Stable Condensing**




# Project #1: Extended Energy Data

- **Existing Building Commissioning complete March 2014**

- Annual Savings: 173,000 kWh/year
- Simple Payback (after incentives): 1.2 years






## Project #2: Adiabatic Cooling


- Many air cooled condensers are marginally sized when new
- 20 year old condenser often ~20% degraded from new
- Garden sprinkler often used to wet condenser on hot days
  - Evaporative cooling: dry bulb versus wet bulb temperature
- Key issues
  - Uneven condensing due to uneven wet/dry area
  - Excessive water usage
- Solution
  - Install “misting” system
    - Even condensing
    - Significant reduction in water usage





## Project #2: Existing Sprinkler






## Project #2: New Misting

- Nozzles installed under the condenser
- Water is forced into a fine mist and quickly evaporates
- Air temperature drops from dry bulb to wet bulb





## Project #2: Utility Savings

- Sprinklers operate from June to September
- Electricity and water / sewage charge savings
- 2,500m<sup>3</sup> = Olympic swimming pool of water


**Table 2: Pre and Post Implementation Values**


Utility	Pre-Implementation† Previous 3 year average	Post-Implementation† 2 year average	Savings	Annual Savings (\$)
<b>Water</b> (Annual Data)	5,618 m <sup>3</sup>	2,879 m <sup>3</sup>	<b>2,739 m<sup>3</sup></b>	<b>\$5,800.00</b>
<b>Electricity</b> (Weekly Data)	17,684 kWh	15,997 kWh	<b>1,687kWh/week</b> <b>25,305kWh/year</b>	<b>\$2,500.00</b>





## Project #2: Water Savings






## Project #3: Variable Flow Compressor


- **Project #3: Variable flow compressor**

- Both existing Refrigeration Racks had one weak Compressor
- Opportunity to upgrade from Constant Flow to Variable Flow Compressor
  - Variable Flow Compressors allow for better load control



Energy Efficient  
Replacement





# Project #3: Pre and Post Energy Data

**TABLE 5: PRE- IMPLEMENTATION PERIOD**

<b>System</b>	<b>Pre-Implementation Period Energy Consumption*</b>	<b>Pre- Implementation Yearly kWh Consumption Estimate</b>	<b>Pre- Implementation Peak kW Demand</b>
LT Rack	263,330	433,441	<b>64.5</b>
MT Rack	181,330	343,274	<b>62.6</b>
Total	444,660	776,715	

\*Pre-Optimization Period is September 1<sup>st</sup> 2013 to April 22<sup>nd</sup> 2014 (223 days)

**TABLE 6: POST- IMPLIMENTATION PERIOD**

<b>System</b>	<b>Post- Implementation Period Energy Consumption*</b>	<b>Post- Implementation Yearly kWh Consumption Estimate</b>	<b>Post- Implementation Peak kW Demand</b>
LT Rack	74,988	386,051	<b>62.6</b>
MT Rack	55,344	267,699	<b>59.6</b>
Total	130,332	653,750	

\*Post Optimization Period is April 23<sup>rd</sup> 2014 to June 30<sup>th</sup> 2014 (69 days)






## Project #3: Business Case

**TABLE 14: SUMMARY OF SIMPLE PROJECT COSTS, OPA INCENTIVES, ANNUAL OPERATIONAL SAVINGS AND SIMPLE PAYBACK CALCULATIONS**

Total Project Cost	\$ 14,100
OPA Incentives (Max 50% of costs)	\$ 7,050
Net Project Cost	\$ 7,050
Estimated Annual savings	\$ 12,740
<b>Simple payback with Incentives</b>	<b>0.6 years</b>
<b>Simple payback without Incentives</b>	<b>1.1 years</b>




# Power Profile: LT System (Baseline, Post Project #1 & 3)






# Power Profile: MT System (Baseline, Post Project #1 & 3)









# SEI: LT System (Baseline & Post Project #1 & 3)





## SEI: LT Sub-Systems (Post Project #3)



★ SEI Compressor

- - Poly. (SEI Compressor)

◆ SEI System


.... Poly. (SEI System )

— Compressor Power

- - Poly. (Compressor Power)




# SEI: MT System (Baseline & Post Project #1 & 3)







# SEI: MT Sub-Systems (Post Project #3)



▲ SEI Compressor


- - Poly. (SEI Compressor)

◆ SEI System

- - Poly. (SEI System)

— Power Compressor

- - Poly. (Power Compressor)




# Sustained Savings

- **No degradation in energy use over 18 months**

➤ System issues identified through monitoring energy change are corrected:

- Helps prevent catastrophic shut-down
- Reduces Store Based Alarms (down ~66%)
- Sustains cost savings







# Opportunities

- **Enclosing medium temperature multi-deck cases**
  - ~\$100/year/linear foot savings
  - New construction: first cost neutral
  - Replacements: <5 year simple payback (>20% ROI)
- **100% LED Vs Linear Fluorescent Lighting**
  - New construction: <4 year simple payback (>25% ROI)
  - Replacement: <6 year simple payback (>15% ROI)
- **Replacing Primary Roof Top Unit (RTU) > 15 years old**
  - <4 year simple payback (>25% ROI)





# Questions?



**Thank You**